

Sl. No.	Parameter	Data type	Address	iACCL 100	iACCL 300
1	Watts Total	float	40101	✓	✓
2	Watts R phase	float	40103	✓	✓
3	Watts Y phase	float	40105		✓
4	Watts B phase	float	40107		✓
5	PF Avg(inst)	float	40117	✓	✓
6	PF R phase	float	40119	✓	✓
7	PF Y phase	float	40121	✓	✓
8	PF B phase	float	40123	✓	✓
9	VA total	float	40125		✓
10	VA R phase	float	40127		✓
11	VA Y phase	float	40129		✓
12	VA B phase	float	40131		✓
13	VLL average	float	40133		✓
14	Vry phase	float	40135		✓
15	Vyb phase	float	40137		✓
16	Vbr phase	float	40139		✓
17	VLN average	float	40141	✓	✓
18	V R phase	float	40143	✓	✓
19	V Y phase	float	40145	✓	✓
	V B phase	float	40147	✓	✓
	Current average	float	40149	✓	✓
	Current R phase	float	40151	✓	✓
	Current Y phase	float	40153	✓	✓
	Current B phase	float	40155	✓	✓
	Frequency	float	40157	✓	
	Wh received	float	40159	✓ Prog	✓ Prog
	VAh received	float	40161	✓ Prog	✓ Prog
	Wh Delivered	float	40167	✓ Prog	✓ Prog
	VAh Delivered	float	40169	✓ Prog	✓ Prog
	Neutral Current	float	40183		✓
	RPM	float	40215	Status	Status